

Message Text

UNCLASSIFIED

PAGE 01 TEGUCI 01248 081750Z

64

ACTION ARA-10

INFO OCT-01 ISO-00 EB-07 /018 W
----- 045060

R 081445Z MAR 76
FM AMEMBASSY TEGUCIGALPA
TO USDOC WASHDC
INFO SECSTATE WASHDC 2710

UNCLAS TEGUCIGALPA 1248

E.O. 11652: N/A
TAGS: BEXP, HO
SUBJ: FOREIGN GOVERNMENT TENDER

1. 215/01/T0023

2. 030376

3. D. MCNALLY

4. 215 HONDURAS

5. N

6A. WRITE TO --

6B. LUIS COSENZA, MANAGER

6C. EMPRESA NACIONAL DE ENERGIA ELECTRICA (ENEE)
DEPARTAMENTO DE PROVEEDURIA
TEGUCIGALPA, D.C., HONDURAS

7. D-514/75

8. 042976 2. PM

9. 201

10. PROPOSAL:

INVITATION TO BID ON SUPPLY AND DELIVERY OF FOLLOWING:
UNCLASSIFIED

UNCLASSIFIED

PAGE 02 TEGUCI 01248 081750Z

3825110-0050. FOURTEEN HUNDRED (1400) WATTHOUR METERS, SINGLE PHASE, SOCKET CONNECTED, 60 CYCLES, 120/240 VOLTS, 3 WIRE, 1 STATOR, 240 V, CLASS 200 4 X 1 POINTER TYPE, REGISTER DIALS AND MULTIPLIER, TEST AMPS 30, FORM 2S, EQUIVALENT TO SANGAMO CAT. J4S; THREE THOUSAND EIGHT HUNDRED (3,800) WATTHOUR METERS, SINGLE PHASE, BOTTOM CONNECTED, 60 CYCLES, 120/240 VOLTS, 3 WIRES, 1 STATOR, 240 V., CLASS 200, 4 BY 1 POINTER TYPE, REGISTER DIALS AND MULTIPLIER, TEST AMPS 30, FORM 2A, EQUIVALENT TO SANGAMO CAT. J3A.

3825161-0005. THREE HUNDRED (300) GLASS COVERS FOR ABOVE METERS.

3825115-0005. TWO HUNDRED SIXTY-FIVE (265) WATTHOUR METERS, 3 PHASE, SOCKET CONNECTED, 60 CYCLES, 240 VOLTS, 4 WIRES DELTA, SELF-CONTAINED, 4 BY 1 POINTER TYPE, REGISTER DIALS AND MULTIPLIER, 2 STATORS, 240 V., CLASS 200, TEST AMPS 30, FORM 15S, EQUIVALENT TO SANGAMO S6S; THIRTY (30) WATTHOUR METERS, 3 PHASE, BOTTOM CONNECTED, 240 VOLTS, 60 CYCLES, 4 WIRE DELTA, TRANSFORMER RATED, 2 STATORS, 240 V, CLASS 10, 4 BY 1 POINTER TYPE, REGISTER DIALS AND MULTIPLIER, TEST AMPS 2.5 FORM 8A, EQUIVALENT TO SANGAMO CAT. S6A; FIFTEEN (15) WATTHOUR METERS, 3 PHASE, BOTTOM CONNECTED 240 VOLTS, 60 CYCLES, 4 WIRE DELTA, TRANSFORMER RATED, 2 STATORS, 240 V., CLASS 10, MECHANICAL DEMAND REGISTER, 4 KW FULL DEMAND SCALE, 1 POINTER TYPE REGISTER DIALS (SWEEP HAND), AND WITH 15 MINUTE TIME INTERVAL, EQUIVALENT TO SANGAMO S6DA; THIRTY (30) KVARH METERS, 3 PHASE, BOTTOM CONNECTED, 60 CYCLES, 240 V., 4 WIRE DELTA, TRANSFORMER RATED, 2 STATORS, 240 V, 4 BY 1 POINTER TYPE REGISTER DIALS AND MULTIPLIER, TEST AMPS, 2.5 CLASS 10, SANGAMO CAT. S6RA.

3825135-0001. THIRTY (30) WATTHOUR DEMAND METERS, 3 PHASE, 60 CYCLES, 4 WIRE STAR, BOTTOM CONNECTED, 3 ELEMENTS, TRANSFORMER RATED 120 VOLTS, CLASS 10 WITH MECHANICAL DEMAND REGISTER 4 KW, FULL DEMAND SCALE, 15 MINUTE INTERVAL, EQUIVALENT TO SANGAMO S4DA.

3825151-0050. TWO (2) METERING OUTFITS, COMPLETE WITH THREE (3) POTENTIAL TRANSFORMERS 20125: 115 RATIO, 175/300: 1 RATED UNCLASSIFIED

UNCLASSIFIED

PAGE 03 TEGUCI 01248 081750Z

THERMAL CAPACITY AT 55 DEGREES C1,500 VA, AND THREE (3) CURRENT TRANSFORMERS 10/20:5 CURRENT TRANSFORMERS SHALL HAVE ACCURACY CLASS 0.3B.0.5 AND POTENTIAL TRANSFORMERS 0.3 Y. INSULATION CHARACTERISTICS OF THE EQUIPMENT SHALL COMPLY WITH THOSE GIVEN IN ANSI STANDARDS FOR THIS VOLTAGE LEVEL.

3612583-0005. FORTY (40) OUTDOOR, CURRENT TRANSFORMERS, WINDOW TYPE, 60 CYCLES, 600 VOLTS, INSULATION CLASS, 10 KV

BIL, ACCURACY CLASS SHALL BE 0.3 B-05, 2X CONTINUOUS
CURRENT THERMAL RATING TRANSFORMERS, 200:5 RATIO; FIFTY
(50) OUTDOOR CURRENT TRANSFORMERS, WINDOW TYPE, 60 CYCLES,
600 VOLTS INSULATION CLASS BIL, 10 KV, ACCURACY CLASS
SHALL BE 0.3 B-05, 2X CONTINUOUS CURRENT THERMAL RATING
TRANSFORMERS, 400:5 RATIO; TWENTY (20) OUTDOOR CURRENT
TRANSFORMERS, WINDOW TYPE, 60 CYCLES, 600 VOLTS INSULATION
CLASS BIL, 10 KV, ACCURACY CLASS SHALL BE 0.3 B-05, 2X
CONTINUOUS THERMAL RATING TRANSFORMERS, 600:5 RATIO.

3643006-0005. ONE THOUSAND TWO HUNDRED (1200) 100 AMP.
SOCKETS, FOUR JAWS WITH OUTDOOR, RAIN TIGHT CABINET SIZE 6
BY 2.75 INCHES; 1 1/4 INCH HUB; RING TYPE COVER, ONE
NEUTRAL CONNECTOR AND SNAP ACTION SEALING RING; FOUR HUNDRED
(400) 200 AMP. SOCKETS, 4 JAWS WITH OUTDOOR, RAIN TIGHT CABI-
NET SIZE 8 BY 4.5 BY 12 INCHES; 2 1/2 INCH HUB, RINGLESS
LATCH TYPE COVER, 2 NEUTRAL CONNECTORS; ONE HUNDRED (100)
100 AMPS. SOCKET, 7 JAWS WITH OUTDOOR, RAIN TIGHT CABINET
SITE 14 BY 8 BY 4.5 INCHES, 2 INCH HUB, RINGLESS LATCH
TYPE COVER, 2 NEUTRAL CONNECTORS; ONE HUNDRED FORTY (140)
200 AMP SOCKETS, 7 JAWS WITH OUTDOOR RAIN TIGHT CABINET
SIZE 16.75 BY 5.68 BY 10 INCHES, 2 1/2 INCH HUB, RINGLESS
LATCH TYPE COVER, 2 NEUTRAL CONNECTORS. ALL SOCKETS SHALL
BE ALUMINUM OR STEEL WITH SERVICE ENTRANCE AT THE TOP AND
FOR 600 V. MAXIMUM VOLTAGE.

3825161-0005. NINETY THOUSAND (90,000) LEAD SEALS WITH
GALVANIZED STEEL WIRES 30 CENTIMETERS IN LENGTH
SUCCESSIVE NUMBERING FROM 110,000 UP TO 200,000 ON ONE
OF FACES AND LETTERING ENEE ON OTHER SIDE.

11. TENDER FINANCED WITH PROCEEDINGS FROM CABEI LOAN TO GOH.
BID AND CONTRACTUAL DOCUMENTS AVAILABLE FROM ADDRESS IN
UNCLASSIFIED

UNCLASSIFIED

PAGE 04 TEGUCI 01248 081750Z

6C. FOR 20 LEMPIRAS (US\$10) FOR TWO SETS EACH OF THESE
DOCUMENTS; POUCHING FOUR (4) SETS TO USDOC.
SANCHEZ

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 JAN 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 08 MAR 1976
Decaption Date: 01 JAN 1960
Decaption Note:
Disposition Action: n/a
Disposition Approved on Date:
Disposition Authority: n/a
Disposition Case Number: n/a
Disposition Comment:
Disposition Date: 01 JAN 1960
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1976TEGUCI01248
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Film Number: D760087-0877
From: TEGUCIGALPA
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1976/newtext/t19760382/aaaacuzc.tel
Line Count: 157
Locator: TEXT ON-LINE, ON MICROFILM
Office: ACTION ARA
Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators: n/a
Previous Classification: n/a
Previous Handling Restrictions: n/a
Reference: n/a
Review Action: RELEASED, APPROVED
Review Authority: ShawDG
Review Comment: n/a
Review Content Flags:
Review Date: 01 SEP 2004
Review Event:
Review Exemptions: n/a
Review History: RELEASED <01 SEP 2004 by meiwc>; APPROVED <08 DEC 2004 by ShawDG>
Review Markings:

Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
04 MAY 2006

Review Media Identifier:
Review Referrals: n/a
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
Secure: OPEN
Status: NATIVE
Subject: FOREIGN GOVERNMENT TENDER
TAGS: BEXP, HO
To: COM
Type: TE
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 04 MAY 2006